

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. **53**

Date: 08/07/2025

It is certified that an inspection team headed by **Dr. Borade Anirudha**, Medical Officer, Primary Health Center, Karade, Tal: Shirur, Dist: Pune From Primary Health Center, Karade, Tal: Shirur, Dist: Pune PHED inspected the **St. Joseph English Medium School, Ramling Road, Shirur, Tal: Shirur, Dist: Pune** on **02/07/2025** and on the basis of Water Test Report (Attached) bearing no **TC125952500001819F & TC125952500001799F** of dated **04/07/2025** of **Biosource Biotech Lab, Pune (PHED Lab)** certified that the **St. Joseph English Medium School, Ramling Road, Shirur** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

This certificate is valid till : **04/07/2026**

Signature with Seal:



ADR
MEDICAL OFFICER
Primary Health Center
Karade Tal. Shirur, Dist. Pune

Name : **Dr. Borade Anirudha**

Designation : **Medical Officer**

Name & Address of Department / office : **Primary Health Center
Karade Tal: Shirur,
Dist: Pune**

To,

**St. Joseph English Medium School,
Ramling Road, Shirur Tal: Shirur,
Dist: Pune.**

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

Manager

St. Joseph English Medium School
Shirur-Ghodnadi, Dist. Pune - 412210
U-dise No. - 27251208628

PRINCIPAL

St. Joseph English Medium School
Shirur-Ghodnadi, Dist. Pune - 412210
U-dise No. - 27251208628



TC-12595



Test Report

Name of Customer : ST. Joseph English Medium School, Shirur
Address of the Customer : Gadekar Park, Ramling Road, Tal. Shirur, Dist. Pune, Maharashtra- 412210
Date of Sample Receipt : 01/07/2025 **Report Issue Date** : 02/07/2025
Sample Code : BSB/2430/W/MBCH/25 **ULR No.** : TC125952500001799F
Name of Sample : Non Filter Water **Analysis End Date** : 02/07/2025
Quantity of Sample received : 1 Liter **Analysis Start Date** : 01/07/2025
Discipline : Chemical & Biological **Sample Given by** : Mr. Sunil Bhukan
Group : Water **Sample Collection Time** : 03.18 pm
Testing Carried out at : Permanent Facility **Condition of Sample** : Sealed (4⁰c)

Result Table

Sr. No	Parameters tested	Observed Value	IS 10500: 2012, RA 2021 Required Standard	Unit	Reference Methods
Physical Parameters					
1	Colour	1	Max. 5	Hazen	IS 3025 (Part-4): 2001
2	Odour	Agreeable	Agreeable	--	IS 3025 (Part-5): 2018
3	pH at 25°C	7.93	6.5-8.5	--	IS 3025 (Part-11): 1983
4	Turbidity	0.1	Max. 1.0	NTU	IS 3025 (Part-10): 1984
5	Total Dissolved Solids	940	Max. 500	mg/lit	IS 3025 (Part-16): 1984
Chemical Parameters					
6	Alkalinity as CaCO ₃	303.8	Max. 200	mg/lit	IS 3025 (Part-23): 1986
7	Total Hardness as CaCO ₃	567.5	Max. 200	mg/lit	IS 3025 (Part-21): 2009
8	Calcium as Ca	115	Max. 75	mg/lit	IS 3025 (Part-40): 1991
9	Magnesium as Mg	68	Max. 30	mg/lit	IS 3025 (Part-46): 1994
10	Chlorides as Cl	112.3	Max. 250	mg/lit	IS 3025 (Part-32): 1988
Microbiological Parameters					
11	E.coli	Absent	Absent	/100 ml	IS 15185: 2016
12	Coliform	Present	Absent	/100 ml	IS 15185: 2016

Opinion: The collected water sample is not within the prescribed limit of Drinking Water Specification IS 10500: 2012, RA 2021 for Above parameters.

-----End of Report-----

Verified & Authorized by
(Biological)


Mr. Vyankatesh Paatil

Note: 1. The above results pertain only to the sample tested & without prejudice of source/process

2. Any correction to this report invalidates the report.

3. This report can not be used for court purpose. We are not responsible for any legal matter.

Issue Date : 01/10/2019 Revision No. 04 Format No. BSB/REC/7.8/021



Verified & Authorized by
(Chemical)

Mrs. Vijaya Kasalkar



Page No.1/1

Manager
St. Joseph English Medium School
Shirur-Ghodnadi, Dist. Pune - 412210
U-dise No. - 27251208628

PRINCIPAL
St. Joseph English Medium School
Shirur-Ghodnadi, Dist. Pune - 412210
U-dise No. - 27251208628



Test Report

Name of Customer : ST. Joseph English Medium School, Shirur
Address of the Customer : Gadekar Park, Ramling Road, Tal. Shirur, Dist. Pune, Maharashtra- 412210
Date of Sample Receipt : 02/07/2025 **Report Issue Date** : 04/07/2025
Sample Code : BSB/2453/W/MBCH/25 **ULR No.** : TC125952500001819F
Name of Sample : Filter Water **Analysis End Date** : 04/07/2025
Quantity of Sample received : 1 Liter **Analysis Start Date** : 03/07/2025
Discipline : Chemical & Biological **Sample Given by** : Mr. Sunil Bhukan
Group : Water **Sample Collection Time** : 02.35 pm
Testing Carried out at : Permanent Facility **Condition of Sample** : Sealed (4⁰c)

Result Table

Sr. No	Parameters tested	Observed Value	IS 10500: 2012, RA 2021 Required Standard	Unit	Reference Methods
Physical Parameters					
1	Colour	1	Max. 5	Hazen	IS 3025 (Part-4): 2001
2	Odour	Agreeable	Agreeable	--	IS 3025 (Part-5): 2018
3	pH at 25 ⁰ C	7.75	6.5-8.5	--	IS 3025 (Part-11): 1983
4	Turbidity	0.1	Max. 1.0	NTU	IS 3025 (Part-10): 1984
5	Total Dissolved Solids	238	Max. 500	mg/lit	IS 3025 (Part-16): 1984
Chemical Parameters					
6	Alkalinity as CaCO ₃	110.7	Max. 200	mg/lit	IS 3025 (Part-23): 1986
7	Total Hardness as CaCO ₃	156.9	Max. 200	mg/lit	IS 3025 (Part-21): 2009
8	Calcium as Ca	36.8	Max. 75	mg/lit	IS 3025 (Part-40): 1991
9	Magnesium as Mg	15.8	Max. 30	mg/lit	IS 3025 (Part-46): 1994
10	Chlorides as Cl	23.9	Max. 250	mg/lit	IS 3025 (Part-32): 1988
Microbiological Parameters					
11	E.coli	Absent	Absent	/100 ml	IS 15185: 2016
12	Coliform	Absent	Absent	/100 ml	IS 15185: 2016

Opinion: The collected water sample is within the prescribed limit of Drinking Water Specification IS 10500: 2012, RA 2021 for above parameters.

-----End of Report -----

Verified & Authorized by
(Biological)
Mr. Vyankatesh Paatil

Note: 1. The above results pertain only to the sample tested & without prejudice of source/process
2. Any correction to this report invalidates the report.
3. This report can not be used for court purpose. We are not responsible for any legal matter.
Issue Date : 01/10/2019 Revision No. 04 Format No. BSB/REC/7.8/021

Verified & Authorized by
(Chemical)
Mrs. Vijaya Kasalkar



Page No.1/1

[Signature]

Manager

St. Joseph English Medium School
Shirur-Ghodnadi, Dist. Pune - 412210
U-dise No. - 27251208628

[Signature]

PRINCIPAL

St. Joseph English Medium School
Shirur-Ghodnadi, Dist. Pune - 412210
U-dise No. - 27251208628